


SUBMITTAL	0403-572A SERIES
0403-622A SERIES	0403-602A SERIES
0403-652A SERIES	0403-642A SERIES

OF SCREWS REQUIRED

CURB	LONG SIDE	SHORT SIDE
0403-572A	8	8
0403-602A	9	8
0403-642A	14	12
0403-622A	20	18
0403-652A	20	18


OF SCREWS REQUIRED

CURB	LONG SIDE	SHORT SIDE
0403-572A	8	8
0403-602A	9	8
0403-642A	14	12
0403-622A	20	18
0403-652A	20	18



OF BOLTS REQUIRED

CURB	LONG SIDE	SHORT SIDE
0403-572A	4	4
0403-602A	4	3
0403-642A	5	4
0403-622A	6	5
0403-652A	6	4



MicroMetl Corporation

PRODUCT NUMBER:
STEEL DECK ANCHORAGE
FLUTES PERPENDICULAR TO FRAMING

STRUCTURALLY CALCULATED ISOLATION
CURB FOR YORK UNITS

Sparks, NV. (800) 884-4662
Indianapolis, IN. (800) 662-4822
Longview, TX. (903) 248-4800

DATE: 07/2007
DRAWN BY: MAC
WEIGHT: XXX
MEETS SEISMIC
REQUIREMENTS FOR
FOLLOWING CODES:
2001 CBC
2006 IBC

THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF MICROMETL CORPORATION. ANY REPRODUCTION IN PART OR WHOLE WITHOUT THE WRITTEN PERMISSION OF MICROMETL CORPORATION, IS PROHIBITED.