


OF SCREWS REQUIRED


CURB	LONG SIDE	SHORT SIDE
W557	10	10
W560	12	9
W564	16	14
W562	23	21
W565	23	21



OF SCREWS REQUIRED

CURB	LONG SIDE	SHORT SIDE
W557	10	10
W560	12	9
W564	16	14
W562	23	21
W565	23	21

SUBMITTAL	W557 SERIES
W562 SERIES	W560 SERIES
W565 SERIES	W564 SERIES



<p>MicroMetl Corporation</p> <p>Sparks, NV. (800) 884-4662 Indianapolis, IN. (800) 662-4822 Longview, TX. (903) 248-4800</p>	<p><i>PRODUCT NUMBER:</i></p> <p>STEEL DECK ANCHORAGE FLUTES PERPENDICULAR TO FRAMING</p>	<p>STRUCTURALLY CALCULATED WELDED CURB FOR YORK CURBS W557, W560, W564</p>
	<p>DATE: 07/2007 DRAWN BY: MAC WEIGHT: XXX MEETS SEISMIC REQUIREMENTS FOR FOLLOWING CODES: 2001 CBC 2006 IBC</p>	

THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF MICROMETL CORPORATION. ANY REPRODUCTION IN PART OR WHOLE WITHOUT THE WRITTEN PERMISSION OF MICROMETL CORPORATION, IS PROHIBITED.